Overhead Electrical Service - Low Building Weatherhead (Customer Owned) **Service Connection Point** (Utility Owned) Guy Wire (Customer Owned) **Overhead Service** House Knob / Wire Service Bracket (Utility Owned) **Anchor** (Customer Owned) Service Mast / Rated for 400# Pull **Entrance Cable** (Customer Owned) Consult NFPA-70, NEC, Sec. **Transformer** 230.28 for service mast structural and support requirements. (Utility Owned) Meter Pole **Meter Socket** (Utility Owned) (Utility Owned) (Customer Owned) The National Electric Code (NEC) 110.26 requires a 30-inch wide space and 36 inches perpendicular to the meter socket be maintained as unobstructed working space. (i.e., this space should be kept clear of shrubs and fences).